



Certificate of Analysis

M.J. Reider Associates, Inc.

ENVIRONMENTAL TESTING LABORATORY
U.S. EPA/PA DEP #06-00003

Laboratory No.: 7000693
Reported: 01/17/17
Lab Contact: Christina Kistler

Attention: Randy Ruffner
Reported To: Mt. Penn Borough Municipal Auth
200 North 25th Street
Reading, PA 19606

Project: Annual NO3, NO2

Lab ID: 7000693-01 **Collected By:** Client
Sample Desc: 101 Carsonia Pump
PADEP Type: E-Entry Point

Sampled: 01/16/17 09:44 **Received:** 01/16/17 10:10

PWSID: 3060082 **Loc ID:** 101

	Result	Unit	Rep. Limit	Procedure	Analyzed	Analyte Notes	Analyst	EPA MCL Min/Max	Pass/Fail
General Chemistry									
Nitrogen, Nitrate	<2.00	mg/l	2.00	EPA 300.0	01/16 16:16		JAE	N/A 4.5	PASS
Nitrogen, Nitrite	<0.20	mg/l	0.20	EPA 300.0	01/16 16:16		JAE	N/A 1	PASS

Lab ID: 7000693-02 **Collected By:** Client
Sample Desc: 102 Sylvan Dell
PADEP Type: E-Entry

Sampled: 01/16/17 09:30 **Received:** 01/16/17 10:10

PWSID: 3060082 **Loc ID:** 102

	Result	Unit	Rep. Limit	Procedure	Analyzed	Analyte Notes	Analyst	EPA MCL Min/Max	Pass/Fail
General Chemistry									
Nitrogen, Nitrate	2.19	mg/l	2.00	EPA 300.0	01/16 16:47		JAE	N/A 4.5	PASS
Nitrogen, Nitrite	<0.20	mg/l	0.20	EPA 300.0	01/16 16:47		JAE	N/A 1	PASS



107 Angelica Street • Reading, PA 19611 • www.mjreider.com • (610) 374-5129 • fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.
NELAP accredited by PA. (PADEP #06-00003) (NYSDOH11630) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.

